

Our Ref: LNO-78972/MATERIAL/SN18524/11-HB

Date: 09 February, 2011

**M/s ALL ASPECTS**

P. O. Box 39613  
Sharjah, U.A.E

Attention: **Mr. Karim Hanna**

E-mail: [aaaim@eim.ae](mailto:aaaim@eim.ae)

Phone: 06-5569913

Subject: **MATERIAL REVIEW REPORT**  
Turboseal P & Turboseal U

Dear Sir,

With reference to your technical submission dated 24 November, 2010 (Submission No. 17355) and 1 February, 2011 (Submission No. 18524); please note that we have **No Objection** on using Turbo-Seal P and Turbo-Seal U as a waterproofing material subject to the following conditions.

- To strictly comply with manufacturer technical recommendations.
- Applicator of the waterproofing system should be approved by the manufacturer.
- Not to use the waterproofing materials in water tanks and planters.
- A Guarantee letter of minimum 15 years should be awarded to every executed project.
- This No Objection is valid for one year from the date of this letter.

Yours faithfully,

**HUSSEIN KHALIL BASMA**  
**SENIOR MANAGER – QUALITY CONTROL**  
**TRAKHEES - PORTS, CUSTOMS & FREE ZONE CORP.**