





<u>CLIENT</u>  DUBAI PARKS & RESORTS PJSC	<u>PROJECT MANAGEMENT</u>  SAMSUNG C&T  Hill International	<u>CONSULTANT</u> Dewan Architects + Engineers	<u>CONTRACTOR</u> 
---	--	--	--

CONTRACT: RIVER PARK RD&E STRUCTURE WORKS (4007)

MATERIAL APPROVAL REQUEST

SUBMITTAL REF:	REV.	DATE	DISCIPLINE
ML-P1-4007-CO-3-ZZZ-T-MAT-00031	00	21/04/2015	Material Submittals

ITEM NO.	DESCRIPTION	MANUFACTURER/ SUPPLIER	LOCATION TO BE USED	Contract Specs/Dwg Ref	Expected Date of arrival on site
1	MaxJoint W-Seal	Drizoro, S.A. Spain / All Aspects Insulation Materials	River Park RD&E Structure Works	River Park RD&E Structure & Utilities Works (4007)	NA

Enclosure:

Sample
 Technical Data
 Test Result/Certificate

Submittal For :


For Approval
 For Information only
 Other

Date Submitted:

Approval Required By: **Dewan CONSULTANTS**

Note: We certify that the material submitted herewith has been reviewed in detail and is in strict conformance with the contract drawing and specification unless as stated otherwise.

Signature



SIGNATURE: KIER PROJECT MANAGER

Dewan Consultant Comments:
Architects + Engineers

- (1) Material is technically acceptable.
- (2) The proposed material has to be compatible with existing waterproofing system used in the sub-structure. Supplier has to confirm it.
- (3) Full compliance statement has to be submitted by the supplier point by point according to the project specification.
- (4) Sample to be sent for Lab Testing for water expansive test.

Signature: _____ Date: _____

SAMSUNG C&T Project Management Comments :

material is not from approved list therefore client approval is required.

Signature: _____ Date: _____

ACTION CODE:

- A. Approved
- B. Approved with comments
- C. Rejected – Revise & resubmit

Signature
26/4/2015

Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions, selecting fabrication processes and techniques of construction, coordinating his work with that of other trades and performing his work in safe and satisfactory manner.

- (5) Contractor to submit warranty certificate for 20 years post POC.
- (6) Contractor to follow manufactures instructions.