

BCC

Form: Material Approval Form (MAF)

Department: General Projects Department



Doc Owner: Head Of Section / Unit

Submittal No. BL/C-009A Rev. 01 Date 25/07/2005 New Submittal Re-submittal

Project No. PJ1160 Project Code End User Client - DM
Project Title Palace for H.H. The Chairman of Dubai Municipality
Consultant Shadid Engineering Consultants Contractor Binladin Contracting Group
Sub-contractor M/s Desert Roofing & Flooring LLC Trade Waterproofing for Water Tanks

Description / Technical Letrate: Waterproofing (MAXSEAL FLEX) for Water Tanks

Attachments Sample Technical Data QA/QC Reports Method Statement Others

Area of Application / Location Underground Water Tanks, Internal Walls & Floors

Specs Ref. GS-7140 Dwg. Ref. - BOQ Ref. Bill No. 21

Origin Spain Manufacturer Name: M/s DRIZORO S.A.

Local Agent M/s DRIZORO Construction Products e-mail / Tel. 06-5569913

Contractor's Attestation

Material / Submittal Comply with Specifications Yes Alternative

Details if Alternative:



Certified By Mufawiz E. Sahawneh Signature / Date [Signature] 25/7/05

For Consultant

Approved
 Approved with Comments
 Rejected
Date forwarded to DM 30/07/2005
Date Received from DM

Comments:
(1) The application to be in the presence of the supplier technical engineer & as per the manufacturer recommendations.
(2) 10 years guarantee to be submitted for approval.
(3) Water leakage test to be carried out after the completion of works for engineers inspection.

Consultant Authorized: [Signature]
Signature / Date:

For Dubai Municipality (DM)

1. Work may proceed.
 2. Revise & re-submit, work may proceed subject to incorporation of comments.
 3. Revise & re-submit, work may not proceed.
 4. Review not required, work may proceed.

Comments:
(1) Materials approved for the drinking water tank.
(2) All applications to be by approved specialist company.
(3) Warranty draft to be submitted.
(4) Recent similar applications list to be submitted showing areas, client and location.
(5) Detailed method statement to be submitted considering safety and quality control requirement.

DM Authorized: [Signature]
Signature / Date: 25/7/05

Note: Dubai municipality permission to proceed does not constitute acceptance or approval of materials developed or selected and does not absolve engineer/contractor and their subcontractors and suppliers from full compliance with contractual obligations including the quality of final product.